



Mr. Eric Delanne
BALSAN
B.P. 50
FR-36330 LE POINCONNET
FRANKRIJK

Your notice of

Your reference

our reference

date

PW/633

2012-03-12

Certification Report Nr. 12/633

1. Description of the flooring:

Product group: Tufted carpet tiles
100% polyamide
Bitumen backing
Total mass: 3955 g/m² - 5980 g/m²
Effective pile thickness: 2.1 mm – 5.4 mm

2. Executed tests:

European Fire classification in accordance with EN 13501-1 (2002)		
Class	EN ISO 11925-2 (15 s surface flame attack) or EN 14041 (2004)	EN ISO 9239-1 (test duration = 30 min)
B _{fl}	E _{fl}	heat flux ≥ 8,0 kW/m ²

3. Conclusion:

Referring to the means of control and the test results, the before mentioned product group can be classified as follows:

loose laid on a non-combustible substrate*

B_{fl} - s1

* End use substrates of classes A1 or A2-s1,d0 (ISO 13238:2010 § 5.2.2)

This certification report runs to 2 pages and may be reproduced, as long as it is presented in its entire form, without written permission of Centexbel.

The results of the analysis cover the received samples. Centexbel is not responsible for the representativeness of the samples.

Centexbel is recognized as notified body 0493 for the European Construction Products directive and the European directive for personal protective equipment

CENTEXBEL GENT
Technologiepark 7
BE-9052 Zwijnaarde (Gent)
Tel. +32 9 220 41 51
Fax +32 9 220 49 55
e-mail gent@centexbel.be

CENTEXBEL BRUSSELS
Montoyerstraat 24-B2
BE-1000 Brussels
Tel. +32 2 287 08 30
Fax +32 2 230 68 15
e-mail brussel@centexbel.be

CENTEXBEL VERVIERS
Avenue du Parc 38
BE-4650 Herve (Chaineux)
Tel. +32 87 32 24 30
Fax +32 87 34 05 18
e-mail chaineux@centexbel.be



Addressee
BALSAN

our ref.
PW/633

date
2012-03-12

page number
2

Related commercial names to this product group are:

BATIK
BOGOLAN
BOLERO
CARRE D'ART
COMPACT
COMPACT PLUS
ECOPILOTE
ECOPIXEL
FACTORY
FRAGMENT
IKAT
IMPACT
IMPRESSION
KILT
LINEA
MEZZO
OMBRA
ORIGAMI
PILOTE
Re. Source
SILVA
SUNRISE
TECHNOPOLE
UPGRADE
ZENITH

The obtained classification is based on the next test reports:

Centexbel: 63951/B of 2008-07-23
Centexbel: 66518/C of 2009-01-09
Centexbel: 74999 of 2010-06-29
Centexbel: 76560/B of 2010-10-13
Centexbel: 81334 of 2011-09-08

Certificate valid until 2013-07-23


Petra Wittevrongel
product certifier