

Client: Shaw Europe Ltd

Summary of Test Report

Identification, basic information and use clarification.			
Product Identity	Ornate Loop Ecworx - 633R3	Date	23/10/18
Manufacturer/applicant	Shaw Industries	Type of surface	Loop Pile
Type of manufacture	Tufted	Secondary backing	PVC
Carpet type (Table 4)	Pile Carpet tile		
Basic Requirements	Pass	Surface Pile Thickness (mm)	4.1
Colouring	Blue/Gold	Surface pile mass (g/m ²)	689
Pile Fibre composition	100% Polyamide	Surface pile density (g/m ³)	0.153
Total Thickness (mm)	8.0	Total carpet mass (g/m ²)	3544
Drum test Hexapod short-term	4.0	Drum test Hexapod long-term	3.5
Test done on underlay	No	Appearance retention class	Class 33
Overall use class	Class 33	Luxury class	LC3
Additional characteristics if applicable			
Castor chair suitability	Intensive	Impact sound insulation (ΔL_w)	25
Thermal resistance (m ² .K/W)	0.090	Sound absorption α_w	0.15
Body voltage walking test (kV)	+1.9	Static dissipative floor covering Ω	Fail
Vertical resistance (Ω)	7.9 x 10 ¹⁰	Conductive floor covering Ω	Fail
Horizontal resistance (Ω)	1.6 x 10 ¹⁰	Resistance to fraying	Pass
Incidental humid conditions suitability	Pass		
Specific information carpet tiles			
Type of tile	Loose Laid	Basic requirements Annex A	Pass
Non adhered/loose laid	Yes	Dimensions of the tile (mm)	---
Adhered removable	Yes	Total mass individual tile (kg)	---
For permanent bonding	Yes	Total mass per unit area (kg/m ²)	3544