

# Attestation

## EMICODE

On 15 May 2014, Eurofins Product Testing A/S received a sample of an underlay with the product name:

### **Oka Lift Super Change Gewebe**

supplied by

### **Kiesel Bauchemie GmbH & Co. KG**

The emission of organic compounds from the sample was measured in accordance with the test method as defined by GEV in its version by 15.04.2013. (See report No.392-2014-00082501A)

#### **Evaluation of the test result according to EC 1 PLUS:**


---

- Carcinogenic substances were not detectable after 3 and after 28 days.
  - The sum of VOC ("TVOC") after 3 days was below the limit of 750 µg/m<sup>3</sup>.
  - The sum of VOC ("TVOC") after 28 days was below the limit of 60 µg/m<sup>3</sup>.
  - The sum of SVOC after 28 day was below the limit of 40 µg/m<sup>3</sup>.
  - After 28 days the value R was calculated from the detected VOC with single concentrations above 5 µg/m<sup>3</sup>. This value R was below the limit of 1.
  - The sum of VOC without LCI-value after 28 days was below the limit of 40 µg/m<sup>3</sup>.
  - The sum of formaldehyde and acetaldehyde after 3 days was below the limit of 0.05 ppm.
- 

This certificate does not alone entitle to use the protected trademark label EMICODE. For the use of an EMICODE label, a license has to be applied for at the GEV, Düsseldorf, Germany.

A license can only be granted for ready-to use products if some additional requirements on contents of certain chemicals (e.g. solvent-free) are fulfilled.

26 June 2014



Janne R. Norup  
Chemist



Søren Ryom Villadsen  
Analytical Service Manager